

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150508-E98049  
**Report Reference** E98049-20010719  
**Issue Date** 2015-MAY-08

**Issued to:** BENDER & WIRTH GMBH & CO  
VOLMESTRASSE 161  
58566 KIERSPE GERMANY

**This is to certify that representative samples of** COMPONENT - LAMPHOLDERS, MISCELLANEOUS (USR, CNR) Component - Lampholder, Miscellaneous, Cat. No. 925

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 496 Lampholders  
CSA-C22.2 No. 43-08 Lampholders

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



## DESCRIPTION

## PRODUCT COVERED:

(USR, CNR) Component - Lampholder, Miscellaneous, Cat. No. 925.

## GENERAL:

These devices are lampholders "for use with Type GX16d base lamps, rated maximum 1500 W, 250 V, 6kV pulse rated".

## ENGINEERING CONSIDERATIONS (NOT FOR UL REPRESENTATIVE USE):

USR indicates investigated to Underwriters Laboratories Standard UL496.

CNR indicates investigated to CSA Standard C22.2 No. 43.

Conditions of Acceptability - The following should be considered in determining the acceptability of the device.

\*1. Consideration should be given to the lampholder lead AWG, **electrical rating**, and temperature rating. The lampholder is supplied with leads rated **18AWG, min. 180°C, 300V if lampholder not marked with pulse rating; 600V rated leads if lampholder is marked with 6kV pulse rating.**

2. The suitability of mounting shall be evaluated in the end-use application.

3. Lampholder, Cat. No. 925 **with 600V rated leads** was subjected to a 6kV pulse dielectric voltage withstand.

Markings - Manufacturer's name, trademark or "E98049", catalog number on device or shipping carton.