

CERTIFICATE OF COMPLIANCE

Certificate Number 20150508-E98049
Report Reference E98049-19990308
Issue Date 2015-MAY-08

Issued to: BENDER & WIRTH GMBH & CO
VOLMESTRASSE 161
58566 KIERSPE GERMANY

This is to certify that representative samples of COMPONENT - LAMPHOLDERS, MISCELLANEOUS
Component - Lampholder, Miscellaneous, Cat. No. 952

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 496 Lampholders
CSA-C22.2 No. 43 Lampholders

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



DESCRIPTION

PRODUCT COVERED:

Component - Lampholder, Miscellaneous, Cat. No. 952.

ENGINEERING CONSIDERATIONS (NOT FOR UL REPRESENTATIVE USE):

Use - The lampholders covered by this report are for use only in complete equipment where the suitability of the combination is determined by Underwriters Laboratories Inc.

Conditions of Acceptability -

1. Spacings of live parts shall meet the spacing requirements of the end use application.
2. The suitability of the lampholder leads shall be determined in end use.

CONSTRUCTION DETAILS:

The general design, shape and arrangement shall be as shown except where variations are specifically described. All dimensions are approximate unless otherwise indicated.

Spacings - Min 3.2 mm through air and over surface between uninsulated live parts of opposite polarity and between uninsulated live parts and dead-metal parts.

Corrosion Protection - All ferrous metal parts are protected from corrosion by painting, plating or the equivalent.

Electrical Ratings -

500 V, 10 A, pulse rated 5 kV.

Marking - Recognized Company's name or trademark and electrical ratings on device. Cat. No. may be on device or on smallest shipping carton.